



January 29, 2019

Temporary Power in a Permanent Location for One and Two-Family Dwellings

The City of Glendale, Arizona allows the installation and use of Temporary Power in a Permanent Location under the following conditions:

1. The panel may be installed at any time during the course of construction and is subject to inspection and approval before being energized.
2. A lockout/tagout procedure is required and enforced by OSHA. A list of personnel trained and responsible for the procedure shall be maintained on site. The contractor or owner will hold the City of Glendale, Arizona, and its employees harmless from any liability or damages occurring from energizing panels through the lockout/tagout program or failure to follow or maintain OSHA required lockout/tagout procedures.
3. Temporary power shall be limited to installing temporary GFCI receptacles adjacent to the SES (Main Panel) location only.
4. The Main Panel shall be de-energized, open, and have the deadfront removed before a final inspection can be made and a Certificate of Occupancy can be issued.
5. The City of Glendale, Arizona will not de-energize or re-energize the system.
6. No occupancy shall be permitted before a Certificate of Occupancy is obtained.
7. If safety is compromised or someone occupies the space without proper approval, the use of Temporary Power in a Permanent Location may be revoked. The Utility Company will be notified by the City of Glendale, Arizona, that safety procedures have not been followed.